



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/675,014	09/30/2003	Randy J. Longsdorf	R11.12-0789	4855

27367 7590 02/08/2007
WESTMAN CHAMPLIN & KELLY, P.A.
SUITE 1400
900 SECOND AVENUE SOUTH
MINNEAPOLIS, MN 55402-3319

EXAMINER

KASENGE, CHARLES R

ART UNIT	PAPER NUMBER
----------	--------------

2125

SHORTENED STATUTORY PERIOD OF RESPONSE	MAIL DATE	DELIVERY MODE
3 MONTHS	02/08/2007	PAPER

Please find below and/or attached an Office communication concerning this application or proceeding.

If NO period for reply is specified above, the maximum statutory period will apply and will expire 6 MONTHS from the mailing date of this communication.

Office Action Summary	Application No. 10/675,014	Applicant(s) LONGSDORF ET AL.	
	Examiner Charles R. Kasenge	Art Unit 2125	

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --

Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 26 October 2006.
- 2a) ☒ This action is **FINAL**. 2b) ☐ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1-55 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1-55 is/are rejected.
- 7) ☐ Claim(s) _____ is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☒ The drawing(s) filed on 30 September 2003 is/are: a) ☒ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some * c) ☐ None of:
1. ☐ Certified copies of the priority documents have been received.
 2. ☐ Certified copies of the priority documents have been received in Application No. _____.
 3. ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).
- * See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- | | |
|---|---|
| 1) <input type="checkbox"/> Notice of References Cited (PTO-892) | 4) <input type="checkbox"/> Interview Summary (PTO-413)
Paper No(s)/Mail Date. _____ |
| 2) <input type="checkbox"/> Notice of Draftsperson's Patent Drawing Review (PTO-948) | 5) <input type="checkbox"/> Notice of Informal Patent Application |
| 3) <input checked="" type="checkbox"/> Information Disclosure Statement(s) (PTO/SB/08)
Paper No(s)/Mail Date <u>10/26/06</u> . | 6) <input type="checkbox"/> Other: _____ |

DETAILED ACTION

Response to Arguments

1. Applicant's arguments filed 9/14/06 have been fully considered but they are not persuasive. The Office reasserts that Eryurek et al. U.S. Patent 6,017,143 discloses a vibration sensor configured to sense vibration signal (Fig. 1 and 2, 16; col. 4, lines 1-4; col. 13, lines 50-54) and the vibration sensor is a process variable sensor (col. 13, lines 3-8 and 50-54).

Claim Rejections - 35 USC § 102

2. The following is a quotation of the appropriate paragraphs of 35 U.S.C. 102 that form the basis for the rejections under this section made in this Office action:

A person shall be entitled to a patent unless –

(b) the invention was patented or described in a printed publication in this or a foreign country or in public use or on sale in this country, more than one year prior to the date of application for patent in the United States.

3. Claims 1-6, 10-26, 28-36 and 39-55 are rejected under 35 U.S.C. 102(b) as being anticipated by Eryurek et al. U.S. Patent 6,017,143. Referring to claims 1 and 32, Eryurek discloses an apparatus for use in an industrial process control or monitoring system, comprising: a process device for coupling to a process (Fig. 2, 40 and col. 3, lines 36-41) which includes a process transmitter (Fig. 1, 8 and col. 3, line 1) or controller (Fig. 1, 10 and col. 3, lines 1) to monitor or control the industrial process and communicate (col. 3, lines 34-36); a process coupling configured to couple the process device to a process which includes piping carrying a process fluid (Fig. 1, 4 and col. 2, lines 66-67); a vibration sensor configured to sense vibrations and provide a sensed vibration signal (Fig. 1 and 2, 16; col. 4, lines 1-4; col. 13, lines 50-54); and diagnostic circuitry (Fig. 5, 102 and col. 8-9, lines 30-14) located in the process device

configured to receive the sensed vibration signal and responsively provide a diagnostic output related to a process disturbance or operation of a process component (Fig. 5 and col. 8, lines 50-52).

Referring to claims 2-6 and 33-36, Eryurek discloses the apparatus of claim 1 wherein the process device includes a process variable sensor for sensing a process variable (col. 4, lines 1-4). Eryurek discloses the apparatus of claim 1 wherein the process device includes a control element configured to control operation of the process (col. 3, lines 36-41). Eryurek discloses the apparatus of claim 1 wherein the process device includes an input configured to receive a process signal (col. 1, lines 44-45). Eryurek discloses the apparatus of claim 1 wherein the process device includes output circuitry including communication circuitry configured to couple to a two-wire process control loop (col. 1, lines 56-57 and col. 13, lines 22-23). Eryurek discloses the apparatus of claim 1 wherein the vibrations are carried through process components (col. 4, lines 1-4).

Referring to claims 10-15 and 39-42, Eryurek discloses the apparatus of claim 1 wherein the output from the diagnostic circuitry is transmitted on a process control loop (col. 2, lines 41-45). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is related to failure of a process component (col. 10, lines 20-28). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is related to degradation in performance of a process component (col. 10, lines 28-31). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is related to an impending failure of a process component (col. 10, lines 28-31). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon a comparison of sensed vibrations to a base line level (col. 12, lines 31-37). Eryurek discloses the apparatus of claim 14 wherein the base line level is determined based upon history of the process (col. 8, lines 29-41).

Referring to claims 16-21 and 43-49, Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon an accumulation of sensed vibrations (col. 12, lines 31-37). Eryurek discloses the apparatus of claim 16 wherein the diagnostic output is based upon a comparison of accumulated vibrations to a threshold (col. 12, lines 31-37). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon trends in the sensed vibrations (col. 10 and 11, lines 62-4). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is used to adjust a control algorithm (col. 2, lines 30-35). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is used to compensate a process variable measurement (col. 4, lines 5-9). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon a frequency spectrum of the sensed vibrations (col. 2, line 52).

Referring to claims 22-26 and 50-53, Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon rules (col. 1, lines 49-64). Eryurek discloses the apparatus of claim 1 wherein the diagnostic circuitry implements a neural network (col. 9, lines 3-5). Eryurek discloses the apparatus of claim 1 wherein the diagnostic circuitry implements fuzzy logic (col. 9, lines 3-5). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon sensed spikes in the vibration signal (col. 1, lines 59-64). Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is based upon a rolling average of the vibration signal (col. 7 and 8, lines 66-1).

Referring to claims 28-31 and 53-55, Eryurek discloses the apparatus of claim 1 wherein the diagnostic output is correlated with process operation (col. 2, lines 41-45). Eryurek discloses the apparatus of claim 1 including a plurality of process devices configured to sense vibrations (col. 4, lines 1-4). Eryurek discloses the apparatus of claim 1 wherein the process device is

Art Unit: 2125

completely powered from a process control loop (col. 4, lines 29-35). Eryurek discloses the apparatus of claim 1 wherein the process device is configured to couple to a process control loop selected from the group of process control loops consisting of two, three and four wire process control loops (col. 2, line 67).

Claim Rejections - 35 USC § 103

4. The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

5. Claims 7-9, 27, 37 and 38 are rejected under 35 U.S.C. 103(a) as being unpatentable over Eryurek et al. U.S. Patent 6,017,143 as applied to claims above, and further in view of Bellet et al. U.S. Patent 5,796,006. Eryurek does not disclose the vibration sensor comprising an accelerometer, configured to sense vibrations along one or more than one axis, and be a piezoelectric sensor. Regarding claims 7-9, 37 and 38, Bellet discloses the apparatus of claim 1 wherein the vibration sensor comprises an accelerometer (col. 4, lines 31-52). Bellet discloses the apparatus of claim 1 wherein the vibration sensor is configured to sense vibrations along one axis (col. 2, lines 33-38). Bellet discloses the apparatus of claim 1 wherein the vibration sensor is configured to sense vibrations along more than one axis (col. 6, lines 33-46). Regarding claim 27, Bellet discloses the apparatus of claim 1 wherein the vibration sensor is selected from a group of vibration sensors including of capacitive, electrodynamic, piezoelectric and Micro-Electro-Mechanical Systems (MEMS) (col. 4, lines 31-52).

At the time the invention was made, it would have been obvious to a person of ordinary skill in the art to have a vibration sensor comprising an accelerometer, configured to sense vibrations along one or more than one axis, and be a piezoelectric sensor. One of ordinary skill in the art would have been motivated to do this since they are commonly used in an industrial process control system (abstract).

Conclusion

6. **THIS ACTION IS MADE FINAL.** Applicant is reminded of the extension of time policy as set forth in 37 CFR 1.136(a).

A shortened statutory period for reply to this final action is set to expire THREE MONTHS from the mailing date of this action. In the event a first reply is filed within TWO MONTHS of the mailing date of this final action and the advisory action is not mailed until after the end of the THREE-MONTH shortened statutory period, then the shortened statutory period will expire on the date the advisory action is mailed, and any extension fee pursuant to 37 CFR 1.136(a) will be calculated from the mailing date of the advisory action. In no event, however, will the statutory period for reply expire later than SIX MONTHS from the mailing date of this final action.


Any inquiry concerning this communication or earlier communications from the examiner should be directed to Charles R. Kasenge whose telephone number is 571 272-3743. The examiner can normally be reached on Monday through Friday, 8:30 - 5 pm.

Art Unit: 2125

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Leo Picard can be reached on 571 272-3749. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free). If you would like assistance from a USPTO Customer Service Representative or access to the automated information system, call 800-786-9199 (IN USA OR CANADA) or 571-272-1000.

CK
November 13, 2006

A handwritten signature in black ink, appearing to read 'L. Picard', with a stylized flourish at the end.

LEO PICARD
SUPERVISORY PATENT EXAMINER
TECHNOLOGY CENTER 2100